



FIRELAB

~ VERIFICATION ~

CERTIFICATE

This is to certify that

Euro Fire Line Vertical Smoke Ventilator

Size: 2 700 mm X 1 400 mm
Blades: Steel & Aluminium
Actuators (IEC/EN, UL and CAN/CSA approved):

- Linear single RACK (IP 55)
- Fail Safe Spring return actuator (IP 54)

is classified as follows

Reliability: Re 1 000
Wind Load: WL 795
Resistance to Heat: B 300
Aerodynamic Free Area: * CFD Modelling of the Fire Line Vertical Louvre FLV EURO 4060 Version 1.1

When tested in accordance with

BSEN 12101-2:2003 - Clause 7

* Clause 6 performed by OFINSOFT (Pty) Ltd

Signed:

Report Number: **FTC 21/196**

Report: 13 October 2016 - FTC 16/006
Verified: October 2021

Report validity: **September 2026**



Reg nr: 2005/087037/23 • Tel: +27 12 349 2929 • info@firelab.co.za

VENTRITE INTERNATIONAL (PTY) LTD
48 FORGE RD, SPARTAN, KEMPTON PARK, GAUTENG • +27 11 975 1333

For detailed information refer to Test Report number FTC 16/006